

Date: 5.12.2007

**Sub: In the matter of enhancement of contract demand from 300 KVA to 500 KVA
on 11 KV in phased manner**

ORDER
(Petition No. 39/07)

M/s Reliance Telecom Ltd., Indore ----- Petitioner

Vs.

M.P.Pashchim Kshetra Vidyut Vitaran Co. Ltd., Indore ----- Respondent

Shri Sunil Dubey , Sr. Manager appears on behalf of the Petitioner.

Shri S.K.Rukmangad, ASE appears on behalf of the Respondent.


2. During the hearing today, the petitioner's representative made a written submission that the available open space in front of the building is the property of M/s Indus Ind Bank Ltd. and the Bank has refused to provide that land to the Company. He has also submitted that the Office of the Superintending Engineer-Electrical Safety and Deputy Chief Electrical Inspector have refused the drawings submitted by them stating as under:


- (a) As per safety norms, clearance between load breaker and transformer should be 1.5 meters as per rules but available space is only 2.5 X 5 meters, so 33 KV sub-station can not be installed.
- (b) Transformer load breaker should be earthed but with the 33 KV system no space is available for earth pits.

3. During the hearing, the respondent's representative has submitted that in case supply is to be given on 11 KV , a 1.6 MVA additional transformer will have to be installed in 33/11 KV Press Complex sub-station at the cost of petitioner.

4. Having heard both the parties, the Commission directs that 500 KVA load on 11 KV cannot be allowed in terms of clause 3.4 of the Electricity Supply Code, according to which the allowable maximum contract demand on 11 KV is 300 KVA.

5. With the above direction, the petition no. 39/07 stands disposed off.


(R.Natarajan)
Member (Econ.)


(D.Roybardhan)
Member (Engg.)


(Dr. J.L.Bose)
Chairman