

Home About Us Acts & Rules Regulations Consumer Service Regulated Entity MPERC Info **Related Links** RTT Act 2005 Non-Conventional Tenders Info Tariff Orders & Petitions Suo Motu Orders Final Orders Approach & Dicussion Papers Contact Details Feedback Form Miscellaneous Info National Electricity Policy Tariff Policy MIS Status Contact Us

Madhya Pradesh Electricity Regulatory Commission

5th Floor, Metro Plaza, Arera Colony, Bittan Market, Bhopal 462 016

Petition No. 13 to 19 of 2007

Sub : In the matter of establishment of Wind Electric Generators (WEG's) `Enercon' make at Ratedi Hills in the Distt. Dewas for sale to M/s M.P. Pasfchim Kshetra Vidyut Vitaran Co. Ltd. as per the orders passed by the Hon'ble Commission

ORDER (Passed on this day 12th June 2007)

Shri D.D. Sharma, authorized representative and Shri U.K. Saharabuddhe appear on behalf of the all the petitioners.

Shri D.K. Ojha, S.E. (Comm.) O/o. CMD (WZ) appears on behalf of the Respondent Company.

2. M/s Enercon (India) Ltd., are developing 90 MW Windfarm project consisting WEG's each having capacity of 800 KW at Ratedi Hills, near Village Karnavad, Distt. Dewas. The windfarm shall be developed by M/s Enercon (India) Ltd., in six groups each having maximum of 15.2 MW capacity, where several investors will own WEGs. The following seven investors has filed separate petition before the Commission in the matter of establishment of Wind Electric Generators (WEG's) 'Enercon' make at Ratedi Hills in the Distt. Dewas for sale to M/s M.P. Pasfchim Kshetra Vidyut Vitaran Co. Ltd.

| S.No | Petition No | Name of Petitioner | Registered Office | No. of WEGs | Location No |
|------|----------------|---|---|----------------|----------------|
| 1 | 13/2007 | M/s Lokhand-wala Shelters India P Ltd. | 72, Gandhi Nagar, Dainik Shiver Road, Worli, Mumbai | 1x 800 kW | 7 |
| 2 | 14/2007 | M/s. CEPCO Industries Pvt Ltd | 8, Balaji Estate, Guru Ravi Dass Marg, Kalkaji, New Delhi | 2 x 800 kW | 11 & 12 |
| 3 | 15/2007 | M/s Lokhand-wala Shelters India P Ltd. | 72, Gandhi Nagar, Dainik Shiver Road, Worli, Mumbai | 2x 800 kW | 4 & 8 |
| 4 | 16/2007 | M/s Ratlam Wires Pvt. Ltd | 72, Gandhi Nagar, Drainage Channel Road, Opp. Municipal Industrial Estate, Worli, Mumbai | 1 x 800 kW | 2 |
| 5 | 17/2007 | M/s Kataria Wires Pvt.Ltd | Plot No. 10-13, Industrial Estate, Ratlam | 1 x 800 kW | 3 |
| 6 | 18/2007 | M/s Kataria Industrial Pvt. Ltd | 72, Gandhi Nagar, Drainage Channel Road, Opp. Municipal Industrial Estate, Worli, Mumbai | 2 x 800 kW | 5&6 |
| 7 | 19/2007 | M/s De Zens Products | 101-D/A, Poonam Chambers, Dr. Annie Besant Road, Worli, Mumbai | 1 x 800 kW | 1 |

3. The petitioners have also made application to the respondent for their approval to connect the WEGs to the grid. The petitioner has also given undertaking that they will submit signed Power Purchase Agreement before connecting to the grid as per draft approved by the Commission. The proposed windfarm will be connected through a 33 KV dedicated external line from 132 KV substation at Chapra.

4. The petitioners prays to the Commission to grant permission to connect to the grid from the date of commission for sale of electricity to M.P. Paschim Kshetra Vidyut Vitaran Co. Ltd., at the rate declared by the Commission vide order dated 01.03.2006 and also to instruct the respondent to sign the PPA. The petitioner salso submitted to the Commission to decide the metering point as the 33 KV switchyard of the windfarm site.

5. During the course of hearing today the respondent M/s MP Pashim Kshetra Vidyut Vitaran Co. Ltd has submitted their reply. The respondent submitted that they will purchase the power generated by the generator to the extent of 0.5% of its requirement as per the directives of the Commission. The respondent also submitted that the petitioners may be directed to sale power to other two Discoms also. The respondent further submitted that permission to connect the generators with the grid will be given after the verification of wind farm site regarding completion of interconnection work, completion of 33 KV bay at EHV S/s as well as installation of WEGs and charging permission of Electrical Inspector is produced. The respondent has also requested that the Hon'ble Commission may decide the metering point so that the same may be incorporated in the agreement.

6. The Commission heard jointly above seven petitions today and decided to pass the following order to be applicable to all the seven petitioners.

7. Considering the facts and circumstances of the case the Commission grants permission to the following petitioners for sale of wind power to the respondent West Discom from the date of commissioning of WEGs at the rate determined by the Commission vide order dated 01.03.2006 subject to it revision (if any) in future.

| S.No | Petition No | Name of Petitioner | No. of WEGs | Capacity | Location No |
|-------|----------------|--|----------------|----------|----------------|
| 1 | 13/2007 | M/s Lokhand-wala Shelters India P Ltd. Mumbai | 1x 800 kW | 0.8 MW | 7 |
| 2 | 14/2007 | M/s. CEPCO Industries Pvt Ltd, New Delhi | 2 x 800 kW | 1.6 MW | 11 & 12 |
| 3 | 15/2007 | M/s Lokhand-wala Shelters India P Ltd. Mumbai | 2x 800 kW | 1.6 MW | 4 & 8 |
| 4 | 16/2007 | M/s Ratlam Wires P. Ltd Mumbai | 1 x 800 kW | 0.8 MW | 2 |
| 5 | 17/2007 | M/s Kataria Wires Pvt.Ltd, Ratlam | 1 x 800 kW | 0.8 MW | 3 |
| 6 | 18/2007 | M/s Kataria Indu. P. Ltd, Mumbai | 2 x 800 kW | 1.6 MW | 5&6 |
| 7 | 19/2007 | M/s De Zens Products, Mumbai | 1 x 800 kW | 0.8 MW | 1 |
| Total | | | 10 x 800kW | 8.0 MW | |

8. The Commission also directs the respondent to connect the petitioner's WEGs with the grid and to execute the PPA. The Commission observes that vide its order dated 17.04.2007 it has already extended the control period for procurement of Wind Energy on the same terms and conditions for a further period till a fresh order is passed by the Commission. The Commission also directs the respondent to install the metering point at the wind farm site till further orders. The Commission further directs the respondent to inspect the wind farm site within three days of the order, with regard to verification of completion of interconnection work, completion of 33 KV bay at EHV S/s as well as installation of WEGs.

9. With the above directions, the Commission decides to close the petitions Nos 13/2007 to 19/2007.

Ordered accordingly.

| Sd/- | Sd/- | Sd/- |
|----------------|----------------|------------|
| (R.Natarajan) | (D.Roybardhan) | (J.L.Bose) |
| Member (Econ.) | Member (Engg.) | Chairman |