

Sub: In the matter of filing petition seeking amendment in clause 3.4 of Chapter 3 “System of Supply and Classification of Consumers” of Madhya Pradesh Electricity Supply Code, 2013

ORDER

(Date of hearing: 9th October,2018)

(Date of order: 10th October,2018)

M.P. Power Management Company Limited, - Petitioner No.1
Shakti Bhawan, Vidyut Nagar, Jabalpur (M.P.)

M.P. Poorv Kshetra Vidyut Vitaran Company Limited, - Petitioner No.2
Block No. 7, Shakti Bhawan,
Vidyut Nagar, Jabalpur (M.P.)

M.P. Paschim Kshetra Vidyut Vitaran Company Limited, - Petitioner No.3
GPH Compound, Polo Ground,
Indore (M.P.)

M.P. Madhya Kshetra Vidyut Vitaran Company Limited, - Petitioner No.4
Bijlee Nagar Colony, Nishtha Parisar, Govindpura, Bhopal

Shri Ambar Pare, Advocate and Shri V.D. Joglekar, GM appeared on behalf of the petitioner no.1.

Shri Deepak Chandela, DGM appeared on behalf of the petitioner no.2.

Shri Shailendra Jain, DD and Shri Kumar Shuubham,AE appeared on behalf of the petitioner no.3.

Shri B.S. Khanooja, GM appeared on behalf of the petitioner no.4.

2. The petitioners, M.P. Power Management Company Limited, Jabalpur and the three Distribution Licensees have filed this petition seeking amendment to clause 3.4 of Chapter 3 “System of Supply and Classification of Consumers” of Madhya Pradesh Electricity Supply Code, 2013. In their petition, the petitioners mainly prayed as under:

“(a) To amend the existing norm of 10,000 kVA as maximum contract demand for supply at voltage level of 33 kV to proposed norm of 15,000 kVA for the consumer who avails power through dedicated feeders.”

3. The case was listed for motion hearing on 09.10.2018. During the motion hearing, the petitioner restated the contents of the petition and requested to consider the issue.

4. Having heard the petitioner and on considering the written submissions, the Commission has noted that:

(i) The relevant portion of the clause 3.4 of the Madhya Pradesh Electricity Supply Code, 2013 provides as follows:

Sub: In the matter of filing petition seeking amendment in clause 3.4 of Chapter 3 “System of Supply and Classification of Consumers” of Madhya Pradesh Electricity Supply Code, 2013

“3.4 The supply voltage for different contract demands shall normally be as follows:

<i>Supply Voltage</i>	<i>Minimum Contract demand</i>	<i>Maximum Contract demand</i>
<i>11 kV</i>	<i>50 kVA</i>	<i>300 kVA</i>
<i>33 kV</i>	<i>100 kVA</i>	<i>10000 kVA</i>
<i>132 kV</i>	<i>5000 kVA</i>	<i>50000 kVA</i>
<i>220 kV or more</i>	<i>40000 kVA</i>	<i>--</i>

Provided that if the licensee is satisfied that there are sufficient grounds for deviation in the norms above stated and such deviation is technically feasible, it may grant the same for reasons to be recorded in writing.”

5. The Commission is of the opinion that in terms of the aforesaid proviso to the clause 3.4 of the M.P. Electricity Supply Code, 2013, the Distribution Licensee may take suitable action to take up the aforesaid issue raised by the consumers. Under the aforesaid circumstances, the Commission does not find it appropriate for any amendment to clause 3.4 of the M.P. Electricity Supply Code, 2013. In view of the above, the petition no. 44 of 2018 stands disposed of.

Ordered accordingly.

(Anil Kumar Jha)
Member

(Mukul Dhariwal)
Member

(Dr. Dev Raj Birdi)
Chairman