



# Madhya Pradesh Electricity Regulatory Commission

5<sup>th</sup> Floor, Metro Plaza, Arera Colony, Bittan Market, Bhopal 462 016

[Home](#)  
[About Us](#)  
[Acts & Rules](#)  
[Regulations](#)  
[Consumer Service](#)  
[Regulated Entity](#)  
[MPERC Info](#)  
[Related Links](#)  
[RTI Act 2005](#)  
[Non-Conventional](#)  
[Tenders Info](#)  
[Tariff Orders & Petitions](#)  
[Suo Motu Orders](#)  
[Final Orders](#)  
[Approach & Discussion Papers](#)  
[Contact Details](#)  
[Feedback Form](#)  
[Miscellaneous Info](#)  
[National Electricity Policy](#)  
[Tariff Policy](#)  
[MIS Status](#)  
[Contact Us](#)

Petition no. 136/2004

**In the matter of L.T. Consumers having sanctioned load above 100 HP to 150 HP but not converted into HT in accordance with Hon'ble MPERC tariff order 2002-03.**

**ORDER SHEET  
dated 14.12.2004**

Shri K.S. Vyas, S.E. (City), MPSEB, Indore appears on behalf of the Board.

Shri R.K. Vyas, Addl. S.E., O/o. CMD (WZ) and Shri Khatri, E.E., O/o CE appears on behalf of Petitioner.

The petition is in the matter of L.T. Consumers having sanctioned load above 100 HP to 150 HP but not converted into HT in accordance with Hon'ble MPERC tariff order 2002-03.

2. The petitioner submits that it was directed by Commission that LT consumers having connected load more than 100 HP may necessarily be given supply at HT upto 30/06/03 but only 54 Nos. consumers came forward for change over from LT to HT.

3. The petitioner further submits that the LT consumers above 100 HP under deposit work or who have installed their own transformer, after paying supervision charges, are not ready for changing over power supply from LT to HT due to financial crises and are paying their energy bill on 11 kV HT tariff with transformer rent and losses @ 3% losses. Therefore the petitioner prays to the Commission to issue necessary instructions and guidance for further action to be taken by such consumers.

4. Commission heard the petitioners. Commission observes that in the new tariff order provision to run upto 150 HP in LT connection is made, which will apply from 1st January, 2005 and till then the consumer has to abide by the present tariff order. In view of the above, Commission directs to close the case.

**Sd/-  
(D.Roybardhan)  
Member (Engg.)**

**Sd/-  
(P.K.Mehrotra)  
Chairman**

Visitors No -  
[FREE WEB PAGE](#)

Last updated: 09/21/2023 05:46:33

**Disclaimer:** While every effort has been made to present accurate information on this website, MPERC does not take responsibility for any error / flaw in the data. MPERC shall be obliged if flaw / omissions are brought to its notice which shall be corrected subsequently.

Site For  
MPERC, BI  
Website optim  
1024 x 768 5