

MADHYA PRADESH ELECTRICITY REGULATORY COMMISSION, BHOPAL

Sub : In the matter of approval to release 60 KVA HT Power at 33 KV level in respect of Sewadham Ashram, Ujjain, a social service organization.

Petition No. 29 of 2010

ORDER

(Date of Hearing : 26th May, 2010)

(Date of Order : 29th May, 2010)

Chief Engineer (UR).,
MP Paschim Kshetra Vidyut Vitaran Co. Ltd.
Jyoti Nagar, Ujjain.

- Petitioner

Shri Ravishankar Khatri, Executive Engineer appeared on behalf of the Petitioner.

2. The petition is in the matter of approval to release 60 KVA HT Power at 33 KV level in respect of Sewadham Ashram, Ujjain, a social service organization. The date of hearing was fixed on 26.05.2010.

3. During the hearing on 26.05.2010, the representative of the Petitioner made a request to allow 60 KVA HT connection at 33 KV for Sewadham Ashram, situated near Ujjain City which provides rehabilitation services to physically and mentally disabled persons and for senior citizen, on humanitarian grounds.

4. As per Clause 1.18 of General Terms and Conditions of High Tension Tariff contained in the Retail Supply Tariff Order for 2009-10, the minimum contract demand at 33 KV should be 100 KVA. Further, the Clause 1.19 of the said tariff order provides that the deviations, if any, in respect of minimum/maximum contract demand may be permitted by the Licensee after obtaining specific approval of the Commission.

5. On hearing the Petitioner, the Commission allows 60 KVA HT connection at 33 KV to Sewadham Ashram, Ujjain as a special case.

6. With the above direction, the Petition No. 29 of 2010 stands disposed off.

Ordered accordingly,

(C.S.Sharma)
Member (Eco.)

(K.K.Garg)
Member (Engg.)