



Madhya Pradesh Electricity Regulatory Commission
5th Floor, Metro Plaza, Arera Colony, Bittan Market, Bhopal 462 016

- Home
- About Us
- Acts & Rules
- Regulations
- Consumer Service
- Regulated Entity
- MPERC Info
- Related Links
- RTI Act 2005
- Non-Conventional
- Tenders Info
- Tariff Orders & Petitions
- Suo Motu Orders
- Final Orders
- Approach & Discussion Papers
- Contact Details
- Feedback Form
- Miscellaneous Info
- National Electricity Policy
- Tariff Policy
- MIS Status
- Contact Us

Petition No. 77 of 2006

SUB: IN THE MATTER OF APPLICATION TO PERMIT 60 KVA LOAD ON 33 KV LINE.

M/s. Vijayvargyai Public Education Society - Petitioner
42, Martand Chowk,
Near Rambag, Indore.
V/s.
M.P. Paschim Kshetra Vidyut Vitaran Co. Ltd., - Respondent
Indore

ORDER SHEET

(As passed on this day of 22nd August, 2006)

Shri Naresh Kumar Jain appears on behalf of Petitioner.

Shri D.K. Ojha, Addl. S.E., O/o CMD (WZ) appears on behalf of M.P. Paschim Kshetra Vidyut Vitaran Co. Ltd., Indore.

2. Petition is filed in the matter to permit 60 KVA Load on 33 KV line.

3. The petitioner submitted that the institute is affiliated to Rajiv Gandhi University, Bhopal. Petitioner has applied to M.P. Paschim Kshetra Vidyut Vitaran Co. to provide connection for 60 KVA from 33 KV line on 06/07/2006 but Superintending Engineer letter dated 11/07/2006 has advised to take permission from MPERC as per H.T. Tariff terms and condition Sl. No. 16 of tariff order dated 31.03.2006 for 2006-07. It is also submitted by the petitioner that it is promoting education activity and its power requirement is only 30 KVA but for the need to get constant voltage supply to run its costly lab equipment safely, petitioner requested to the West Discom to provide connection for 60 KVA from 33 KVA line. There is no 11 KVA line available near by. As per terms and condition Sl. no. 16, Commission's permission is required for a deviation from the minimum contract demand. Therefore petitioner prays to the Commission to direct the West Discom to provide the connection for 60 KVA load on 33 KV.

4. Respondent did not submit the reply. During the course of hearing today, the representative of the respondent Shri D.K. Ojha informed that he has not received the notice of this particular case. It is observed by the Commission that notice had been sent to the respondent West Discom clearly directing to indicate if there is any technical difficulty in providing low range metering equipments at 33 KV for catering to a load of 30 KVA (60 KVA-CD) or else metering provided on L.T. side. Commission directs respondent to submit the reply on the next date.

5. Next date of hearing is fixed for 12/09/2006.

Sd/-
(R.Natarajan)
Member (Econ.)

Sd/-
(D.Roybardhan)
Member (Engg.)

Sd/-
(P.K.Mehrotra)
Chairman